

Datenblatt für Artikel: HSELS48SCP

Optikai rendező, 48 szál, SC, 50/125µm OM5, 19", 1U, Class C

megfelel IEC 61753-1, RAL7035, CLASSIC



Schrack-Info

These spliceboxes are delivered assembled with already installed couplers and enclosed pigtails (all connectors come with ceramic ferrule).

The spliceboxes are depth-adjustable using the two 19" brackets.

The spliceboxes have one, two or four splice trays depending on the number of fibres with integral splice organisers for shrink-on splice protectors and is designed for up to 4 cable entries, equipped with one M20 cable entry by default.

Blind covers are used to close off unused cable entry ports.

Two versions for up to 48 fibres in a sliding tray design are available:

- with 24 LC-Duplex couplers
- with 24 SC-Duplex couplers
- Material: zinc-coated steel
- Installation: 19", 1U
- Dimensions W x H x D: 483 x 44 x 240mm
- Housing color: RAL7035 Light grey
- Color of couplers (LC and SC): Lime-green
- Dustcovers (LC and SC): Included

Technische Daten

Nettó szélesség (mm)

480,00

Technische Daten - Fortsetzung

Nettó magasság (mm)	44,00
Nettó mélység (mm)	242,00
Nettó tömeg (kg)	2,53
Szál	50/125 OM5 Multimode
Szín	RAL 7035 (világos szürke)
Jellemző bemeneti veszteség (dB)	< 0,2
Jellemző visszaverődési veszteség (dB)	> 35
Min. környezeti hőmérséklet (°C)	-10
Max. környezeti hőmérséklet (°C)	70
Szálszám	48

Artikeltabelle

BEZEICHNUNG	BEST.NR.
Optikai rendező, 48 szál, SC, 50/125µm OM5, 19", 1U, Class C megfelel IEC 61753-1, RAL7035, CLASSIC	HSELS48SCP
Választható tartozék	
Optikai hegesztésvédő zsugorcső, 60mm	HELSP00011
Optikai hegesztésvédő zsugorcső, 40mm	HELSP00010
Optikai tisztító eszköz SC, ST,FC és E2000 Használható UPC és APC csatlakozókhoz. Több mint 1000 tisztítási ciklus.	HSELSZT002
Opt. teljesítménymérő beépített lézeres fényforrással (VFL) RJ45 réz kábelteszt. FIGYELEM: Ez egy 2. osztályú lézertermék. Ne nézzen a lézersugárba. A VFL port fedele mindig legyen rajta, HSELSZT003 amikor nincs használatban. Optikai szálak rendszerekkel végzett munka során ajánlott lézer-védőszemüveg használata.	